

ECLIPSE
Reverse Osmosis
Drinking Water System

Installation, Operation & Service Manual

WRO-35

R.O. Drinking Water System



Tested and Certified by NSF International against NSF/ANSI Standard 58 for the reduction of the claims specified on the Performance Data Sheet.

TABLE OF CONTENTS

| | Page |
|--|------|
| SECTION I. INTRODUCTION | 3 |
| SECTION II. SPECIFICATIONS | 4 |
| SECTION III. PREPARATION | 5 |
| A. Major System Components..... | 5 |
| B. Tools Recommended for Installation | 7 |
| C. Site Selection For Major System Components | 7 |
| SECTION IV. INSTALLATION STEPS | 8 |
| A. Faucet with Water Quality Monitor Installation | 8 |
| B. Feed Water Saddle Valve Installation..... | 10 |
| C. Drain Clamp Installation..... | 10 |
| D. R.O. Manifold Assembly Installation..... | 11 |
| E. Position the Drinking Water Holding Tank and Make the Final Hose Connections | 12 |
| F. Start Up..... | 13 |
| SECTION V. OPERATION AND MAINTENTANCE | 13 |
| A. Normal Operation..... | 13 |
| B. Changing Modules | 14 |
| C. Changing the In-Line Activated Carbon Post Filter | 14 |
| SECTION VI. TECHNICAL DATA..... | 14 |
| A. Water Quality | 14 |
| B. Water Quantity | 15 |
| C. Net Pressure Differential | 15 |
| D. Water Production Rate Chart..... | 17 |
| SECTION VII. TROUBLE SHOOTING GUIDE | 18 |
| EXPLODED VIEW AND PARTS LIST | 21 |

CAUTION:

The Centers for Disease Control and Prevention (CDC) and the Environmental Protection Agency (EPA) have issued guidance to people with severely weakened immune systems who may want to take extra precautions to reduce the risk of infection with *Cryptosporidium* from drinking water. This guidance pertains to people with HIV/AIDS, patients receiving treatment for cancer, recipients of organ or bone marrow transplants, transplant patients taking immunosuppressive drugs, and persons who have congenital immunodeficiencies.

The EPA has stated that they do not know the significance of drinking water compared to other possible sources of *Cryptosporidium* to determine how most people become infected. The CDC-EPA guidance suggests that immunosuppressed individuals discuss their risks with their health care provider.

This drinking water system is tested and Certified by NSF International to NSF/ANSI Standard 58 for cyst reduction. It meets the NSF/ANSI standard of reducing at least 99.95%* of cysts (including *Cryptosporidium*), however, because this is not 100%, immunosuppressed individuals should take the extra precaution of boiling their drinking water. According to the CDC-EPA, bringing water to a rolling boil for one minute is the most certain approach for killing *Cryptosporidium*.

All individuals should take adequate precautions when changing the filter cartridges, including wearing protective gloves, to avoid direct contact with the exhausted cartridges.

*For complete specifications, refer to the Performance Data Sheet.

SECTION I. INTRODUCTION

Your new Reverse Osmosis (R.O.) Drinking Water System uses a combination of filtration technologies to reduce unwanted contaminants in a water supply. The following steps combine to give you the best in clear sparkling drinking water:

MECHANICAL FILTRATION/ACTIVATED CARBON—The Sediment/Carbon Module will remove the larger particles such as silt, rust and scale. Its 5 micron (equal to 0.0002 inch) nominal rating helps to give maximum life to the R.O. Membrane. The activated carbon in the Prefilter will remove any chlorine that may be present in the feed water. This pretreatment is also necessary for membrane protection.

REVERSE OSMOSIS MEMBRANE—The R.O. Membrane is the heart of the filtration system. It is designed to reduce the dissolved mineral content of the water. Minerals picked up in the environment by the water are measured as Total Dissolved Solids (TDS). In the Reverse Osmosis process, dissolved minerals are separated from the incoming water (Feed Water) to produce the product water (the Permeate). The excess minerals are rinsed to drain (the Reject Water).

The membrane is a specially constructed, fully aromatic polyamide film, and is classified as a Thin Film Composite (T.F.C.).

The spiral wound construction of the R.O. Membrane provides maximum surface area for water production and is less susceptible to fouling by particulate matter, turbidity and colloidal materials.

ACTIVATED CARBON—The Activated Carbon Module contains carbon particles with a vast network of pores. The tremendous surface area of these pores (typically 800–1200 square meters per gram of carbon) gives the carbon

very good adsorptive sites for substances that contribute to tastes and odors.

IN-LINE ACTIVATED CARBON POST FILTER—The In-Line Activated Carbon Post Filter is located after the Holding Tank and reduces the tastes and odors that may pass through the system. It adds a final polish to the water.

AUTOMATIC SHUTOFF VALVE—The ASO Valve senses when the Holding Tank is full and closes the feed water supply to prevent excess reject water from going to drain when the unit is not producing water.

WATER QUALITY MONITOR—The Water Quality Monitor has been integrated into the faucet base for instant monitoring at the touch of a button. The monitor compares the level of the Total Dissolved Solids in the incoming (feed) water versus the product water and calculates the percent rejection. The monitor is preset to indicate a level of 75% rejection.

A green light indicates that the percent rejection is at or above the set (desired) value and that the system is producing quality water.

An amber light indicates that the product water quality is less than acceptable. Because the Water Quality Monitor was designed to operate best while the system is making water, a false reading may occur if tested when your R.O. drinking water system is not making water. Please empty the Holding Tank, wait 15 minutes for the system to begin making water, and test your water quality again. If the Water Quality Monitor light is still amber, please contact a water treatment professional for service. The Water Quality Monitor requires a 9 volt battery, which is included.

IMPORTANT NOTICES:

This reverse osmosis system contains replaceable treatment components critical for effective performance. It is the user's responsibility to, and the manufacturer strongly recommends that the user, periodically test the product water to verify the system is performing satisfactorily. See the test kit(s) for sampling instructions.

This system is acceptable for treatment of influent concentrations of no more than 27 mg/l nitrate and 3 mg/l nitrite in combination measured as N and is certified for nitrate/nitrite reduction only for water supplies with a pressure of 40 psig (280 kPa) or greater.

This system conforms to NSF/ANSI Standard 58 for pentavalent arsenic reduction. See the Performance Data Sheet and Arsenic Facts section for an explanation of reduction performance.

DO NOT USE WITH WATER THAT IS MICROBIOLOGICALLY UNSAFE OR OF UNKNOWN QUALITY, WITHOUT ADEQUATE DISINFECTION BEFORE OR AFTER THE SYSTEM. Systems certified for cyst reduction may be used on disinfected water that may contain filterable cysts.

SECTION II. SPECIFICATIONS

TABLE A – QUALIFIED SYSTEM PERFORMANCE

Because the performance of an R.O. Membrane is highly dependent upon pressure, temperature and TDS, the following should be used for comparison purposes only.

| | U.S. | Metric |
|-------------------------------------|--------------------|--------------------|
| Membrane Production ¹ | 35 ± 7 gpd | (106–159 lpd) |
| Membrane TDS Reduction ¹ | 95% minimum | 95% minimum |
| System Production ² | 11 gpd | 42 lpd |
| TDS Reduction ² | 90%+ typical | 90%+ typical |
| Drain (reject water) Flow | 3–5 x product flow | 3–5 x product flow |
| Empty Storage Tank Precharge | 5–7 psig air | 35–48 kPa air |
| Storage Tank Capacity ² | 1.8 gallons | 6.8 liters |

¹ Industry standards measure RO Membranes performance with no backpressure on the product water, at 60 psig (414kPa) and 77°F (25°C). Further conditions on the above are 250 ppm TDS and a 15% recovery rate. Production rate and TDS reduction figures are for a new Membrane that has been rinsed for 24 hours. The production rate of a new Membrane can decrease by 10% per year or more, depending upon the scaling and fouling tendencies of the Feed Water.

² Measured at 50 psig, 77°±2°F, and 717 mg/l TDS per NSF/ANSI Standard 58.

TABLE B – RECOMMENDED OPERATING LIMITS FOR FEED WATER

| Specifications | T.F.C. Membrane |
|------------------|---------------------------------------|
| Water Pressure | 40–100 psig (280–690 kPa) |
| TDS | 2000 ppm (also mg/l) max. |
| Temperature | 40–100°F (4–38°C) |
| pH | 3–11 |
| Hardness | Less than 10 gpg (170 mg/l) or soften |
| Iron | Less than 0.1 ppm (also mg/l) |
| Manganese | Less than 0.05 ppm (also mg/l) |
| Hydrogen Sulfide | None |
| Chlorine | See note |
| Bacteria | Must be potable** |

NOTE: Chlorine will damage a T.F.C. Membrane. The Sediment/Carbon Module will remove chlorine from the incoming water. Change filter every 6 months, more often if the water contains more than 1 ppm chlorine.

****DO NOT USE WITH WATER THAT IS MICROBIOLOGICALLY UNSAFE OR OF UNKNOWN QUALITY, WITHOUT ADEQUATE DISINFECTION BEFORE OR AFTER THE SYSTEM.**

SECTION III. PREPARATION

A. Major System Components

The following components comprise the R.O. Drinking Water System. (Refer to Fig. 1, below for general system layout.)

- An R.O. Manifold assembly.
- Housings and Housing O-rings.
- A Drinking Water Holding Tank.
- A Dispensing Faucet with Water Quality Monitor Assembly.
- A Feed Water Saddle Valve.
- A Drain Clamp.
- Plastic Tubing and tube connectors.
- A Reverse Osmosis Membrane sealed in a plastic bag.
- A Sediment/Carbon Module, shrink wrapped.
- An Activated Carbon Module, shrink wrapped.
- An In-Line Activated Carbon Post Filter, shrink wrapped.
- Other items necessary for installation may include wood screws or machine screws and nuts for mounting the manifold, or concrete anchors for hanging on basement wall. Additional tubing or tube connectors. Plastic wire ties for organizing tubing.

TYPICAL WRO-35 UNDER SINK INSTALLATION DIAGRAM





Figure 1

OPTIONAL WRO-35 BASEMENT INSTALLATION DIAGRAM



B. Tools Recommended for Installation

The following tools will cover most of the installation sites encountered:

1. $\frac{3}{8}$ " variable speed electric drill.
2. Extension work light with outlet.
3. Safety glasses.
4. $\frac{1}{4}$ " porcelain hole cutter kit.
5. $\frac{1}{4}$ " Greenlee hole punch and $\frac{1}{8}$ " and $\frac{1}{2}$ " metal drill bits for pilot hole.
6. Center punch and hammer.
7. $\frac{1}{4}$ " wood bit.
8. Concrete drill bits.
9. Assorted wood and metal drill bits including $\frac{7}{32}$ " metal drill bit.
10. Phillips head and flat blade screwdrivers.
11. $\frac{1}{2}$ ", $\frac{9}{16}$ " and $\frac{5}{8}$ " open end wrenches.
12. 10" Crescent wrench with jaws taped to hold faucet.
13. Basin wrench or 10" pipe wrench.
14. Teflon tape.
15. Wide masking tape or duct tape.
16. Plastic tubing cutter.
17. Extra plastic tubing.
18. Low range air pressure gauge.
19. Bicycle hand air pump.
20. Small bottle of liquid chlorine bleach.
21. Graduated measuring cylinder.
22. Paper towels, wisk broom and assorted clean up materials.

C. Site Selection for Major System Components

The R.O. System was designed to fit under a sink, however, because of space limitations or other reasons, the system's flexible design allows for other locations. When determining the location remember that access to a cold water tap line, the household drain, and ease of filter replacement are important considerations.

All components and tubing should be located in an area not exposed to freezing temperatures. If winter temperatures are severe, the area should be above the minimum temperature listed in Table B, page 4 for proper performance. Do not expose unit or tubing to direct sunlight.

1. **Dispensing Faucet**—The faucet should be placed near the sink where drinking water is normally obtained. Convenience of use (filling of water pitchers and glasses), and an open area beneath the faucet under the sink for attaching product and drain tubing are considerations. A 2" diameter flat surface is required above and below the installation site. The thickness of the mounting surface should not exceed $\frac{1}{4}$ ". Watch for strengthening webbing on the underside of cast iron sinks.
2. **Drinking Water Holding Tank**—The Holding Tank may be placed where it is convenient within 10 feet of the faucet; under the sink or in an adjacent cabinet are best the choices. If a longer run of tubing is required, the tubing should be the $\frac{3}{8}$ " diameter OD size to prevent a high pressure drop. Remember, these tanks can weigh up to 30 pounds when full of water; a firm, level area is required.
3. **R.O. Manifold Assembly**—The manifold can be installed on either the right or left side of the under-sink area or a cabinet. The right side is recommended because all the tubing will be to the back of the cabinet and out of the way. Installation in the basement is also an option; one location is near the laundry/utility sink where cold potable water and drain access are handy. The mounting location should allow adequate clearance and accessibility for cartridge changes.
4. **Feed Water Connection**—The Feed Water Saddle Valve should be located as close to the manifold assembly as possible. USE A POTABLE COLD WATER SUPPLY ONLY. Softened water is preferred as it will extend the life of the R.O. Membrane.
5. **Drain Connection**—The waste water must go to drain through an anti-siphon air gap. The air gap is provided for in the base of the faucet. If discharging into a utility sink or standpipe, an air gap of greater than 1" above the flood rim must be provided.

Do NOT connect the system drain line to the dishwasher drain or near the garbage disposal. Backpressure from these units may cause the air gap to overflow.

SECTION IV. INSTALLATION STEPS

All plumbing should be done in accordance with state and local plumbing codes.

NOTE: Some codes may require installation by a licensed plumber; check with the local plumbing authority prior to installation.

In restricted under-sink areas, it may be easier to install the faucet first. Allow adequate tubing lengths for any final component position.

A. Faucet With Water Quality Monitor Installation

–The faucet contains an anti-siphon air gap. While the system is producing water, the drain water flows from the R.O., through the air gap and then to the household drain. The purpose of the air gap is to prevent water in the drain from backing up into the R.O. Drinking Water System.

NOTE: For proper installation the Air Gap Faucet has a critical level line “CL” marked on its body and should be mounted so that the “CL” line is at least one (1) inch (26mm) above the flood level rim of the sink.

The easiest installation is to use an existing spray attachment hole. If the spray faucet hole is not available, then the sink top must be drilled. Choose a convenient location as described in Sec. III, C.1, page 7.

1. Mark the location of the center of the faucet base.

2a. Drilling a stainless steel sink:

- Center punch the hole to provide a starting point for the drill.
- Start with a smaller drill as a pilot, and then drill a ½" diameter hole to accept the bolt of a 1¼" Greenlee Hole Punch (1¼" chassis punch).
- Clean away any chips.
- Install the punch and tighten the nut to cut the hole.
- Deburr any sharp edges.

2b. Drilling a porcelain sink:

It is best to use a special 1¼" diameter cutter designed for porcelain. A carbide tipped masonry bit is a second choice.

- Place a piece of tape over the area to be drilled to help prevent chipping.
- Drill a pilot hole for the porcelain cutter. Use the pilot drill supplied with the kit or a

carbide tipped drill.

- When drilling the 1¼" hole, drill slowly and carefully; the porcelain chips easily.
- After drilling, clean the area well. Iron filings, if left in place, can cause rust stains.

2c. Drilling a counter top:

NOTE: The counter top must be less than 1¼" thick. Treat ceramic tile as porcelain until the tile is penetrated, then use the carbide tipped metal cutter.

Formica counter tops may be drilled with a good 1¼" wood bit; drilling a ¾" pilot hole will help keep the bit going straight.

3. Assemble and attach the Faucet, Water Quality Monitor Faucet Base and tubing (refer to Fig. 2A & 2B, page 9.)

- Assemble the Body and Spout by removing the plastic shipping plug from the Body and then firmly pressing in the Spout.



Locate the ¼" Black Drain Tubing which is shipped loose in the box. Connect the Black Drain Tubing to the ¼" Hose Barb on the Dispensing Faucet by firmly pressing over the barb. Allow the tubing to relax, then press firmly again to insure proper seating. The end of the Black Drain Tubing that should be inserted into the "Drain" port on the R.O. Manifold will have a blue drain restrictor in it. DO NOT attach this end to the Dispensing Faucet.

Locate the ¾" Black Drain Tubing which is shipped loose in the box. Firmly press one end of the tubing over the ¾" drain outlet hose barb on the Dispensing Faucet. Allow tubing to relax, then press firmly again to insure proper seating. No connectors are required when attaching tubing to Hose Barbs.

Slide Water Quality Monitor Faucet Base over ¼" Black Drain Tubing, ¾" Black Drain Tubing and 7/16" stud screw and seat with Amber/Green LED's aligned under Air Gap Window on Dispensing Faucet. (See Figure 2A, page 9.)

Assemble the Plastic Spacer (with open end upwards and facing tubing), the 7/16" Washer and the 7/16" Hex Nut onto the 7/16" stud screw. Do Not tighten at this point.

LONG REACH AIR GAP FAUCET WITH WATER QUALITY MONITOR



- From the top of the counter place the stud, tubing and Water Quality Monitor Connector Cable through the mounting hole. See Figure 2B, page 9.

- From the bottom of the counter top slide the Slotted Washer between the counter top and the Plastic Spacer with the open end towards the tubing.

Tighten the $\frac{7}{16}$ " Hex Nut to hold everything in place.

- Rotate the Spout and Body into position making sure the faucet body is square and properly aligned with the Water Quality Monitor Faucet Base. Align the Slotted Washer and the Spacer to allow access to the Hose Barbs, and tighten the Hex Nut while holding the faucet in alignment with a padded crescent wrench. Do not over tighten.

- To the end of the $\frac{7}{16}$ " stud, screw on the $\frac{3}{8}$ " Polytube Quick Connect Fitting. Once snug by hand take a pair of pliers and tighten the fitting an additional half turn. Don't over tighten.

Locate the $\frac{3}{8}$ " Blue Product Water Tubing. Firmly press one end into the $\frac{3}{8}$ " Polytube Quick Connect Fitting.

Note: If you want to pull the tubing out for some reason, push the ring around the tubing in and pull the tubing out.

B. Feed Water Saddle Valve Installation

Decide on location. Do NOT connect to a hot water feed line. If you are not sure of the supply, run the hot water and feel the supply piping. Water over 100°F may cause permanent damage to the R.O. Membrane. (Refer to Fig. 3 page 11.)

1. Shut off the water supply and drain the line.

2a. To install on (soft) Copper Tubing supply line:

- Turn the Handle of the Feed Water Saddle Valve counter clockwise (outward) until the lance does not protrude from the gasket. It may have to be pushed in.

- Assemble the Feed Water Saddle Valve on the tubing.

–for $\frac{3}{8}$ " OD tubing use the back plate side with the small groove to prevent distortion of

the tubing.

–for larger tubing (up to $\frac{5}{8}$ " OD) use the large groove of the back plate.

- Assemble and tighten the brass screw.

- To pierce the tubing, turn the Valve Handle fully clockwise (inward). A small amount of water may escape from the outlet until it is fully pierced.

- When you feel the Valve Handle firmly seated in the clockwise direction, the copper tube is pierced and the valve is closed.

2b. To install on (hard) Steel or Brass Tubing supply line.

- The supply line should now be drained. Use a battery powered or properly grounded drill to avoid shock hazard.

- Drill a $\frac{3}{16}$ " hole in the supply line; (do not drill through the opposite wall).

- Turn the handle to expose the lance no more than $\frac{3}{16}$ " beyond the rubber gasket.

- Place the body of the valve over the hole so that the lance fits into the hole.

- Assemble and tighten the brass screw.

- Turn the Valve Handle clockwise (inward) until firmly seated. The valve is closed.

3. With the Feed Water Saddle Valve closed, open the sink faucet and the water supply and allow the water to run for a few minutes to flush any debris caused by the installation.

- Close the faucet and check the Feed Water Saddle Valve for leaks.

C. Drain Clamp Installation

Choose the drain outlet location per Sec. III, C.5, page 7.

The following are instructions for discharging into the sink drain pipe. (Refer to Fig. 1, page 5.)

1. Position the Drain Clamp on the sink drain pipe above the drain trap. Allow room for drilling. Tighten securely.

2. Use a battery powered or properly grounded drill. Using the Clamp port as a drill guide, drill a $\frac{7}{32}$ " hole through the wall of the drain pipe. Do NOT penetrate the opposite side of the pipe.

3. Locate the $\frac{3}{8}$ " Black Drain Tubing connected

to the Dispensing Faucet. Route to the tubing to the Drain Clamp and trim to length.

NOTE: When cutting the polytubing make clean, square cuts, failing to do so could result in poor connections and possible leaks.

CAUTION: The lowest point of the line should be the point of connection to the Drain Clamp. There should be no sag in the line as this may cause excessive noise as the reject water is flowing to drain.

•Refer to Fig. 4, page 12. Insert the tubing into the Drain Clamp. Make sure the tubing is pressed all the way in to create a pressure tight connection.

NOTE: If you want to pull the tubing out for some reason, push the ring around the tubing in and pull the tubing out.

D. R.O. Manifold Assembly Installation

Locate the site per Sec. III, C.3, page 7. Various installation sites will require different types of mounting fasteners; be sure the fastener selected will provide a firm, solid mounting. A support panel may be necessary on thin cabinet walls or to span between wall studs on particleboard or drywall.

Do not drill through exterior cabinet walls or leave sharp wood screw points exposed in readily accessible cabinet interiors.

The close proximity of a dishwasher or a trash compactor may require special fabrication of a mounting plate.

1. The mounting bracket will accept either #10 or #12 (5mm) mounting screws spaced on 6" (15 cm) centers. Allow at least 4" (10 cm) of clearance beneath the filter housings to accommodate filter changes. Mark the two locations (the bracket can be used as a template). Install the screws and tighten them until the heads are about $\frac{5}{8}$ " from the wall.
2. Locate the $\frac{1}{4}$ " Red Feed Water Tubing. Remove the red plug from the fitting labelled "In" on the manifold and insert the tubing. Reference the special supplement sheet in the carton for proper connection of all tubing and removal of plugs. Run the tubing along its course to the Feed Water Saddle Valve, trim to length. (Refer to Fig. 1, page 5.)

Refer to Fig. 3,. To the end of the red polytube install the Compression Nut, the Plastic Ferrule, and the Insert. Connect to the Feed Water Saddle Valve.

3. Locate the $\frac{1}{4}$ " Black Drain Tubing connected to the Dispensing Faucet. Remove the black plug from the fitting labelled "Drain" on the manifold and insert the tubing. The end of the Black Drain Tubing that should be inserted into the "Drain" port will have a blue drain restrictor in it. If tubing needs to be trimmed

FEED WATER SADDLE VALVE




Figure 3

3/8" DRAIN CLAMP ASSEMBLY




Figure 4

to length, carefully slit 1/4" Black Drain Tubing end that has the blue drain restrictor in it being careful not to damage the hose barb on the drain restrictor. Remove restrictor from tubing, make a square cut, and reinsert the drain restrictor. Allow the tubing to relax, then press drain restrictor firmly again to insure proper seating.

4. Locate the 1/4" yellow tubing with the tee attached to one end. Remove the yellow plug from the fitting labelled "Out" on the manifold and insert the tubing.
5. Locate the 3/8" Blue Product Water Tubing attached to the Dispensing Faucet. Firmly press one end into the tee. (Refer to Fig. 1, page 5.) The fittings will grab the tubing and seal it in place. Make sure the tubing is pressed all the way in to create a pressure tight connection.
NOTE: If you want to pull the tubing out for some reason, push the ring around the tubing in and pull the tubing out.
6. Hang the Manifold Assembly on the mounting screws and tighten. **DO NOT OVERTIGHTEN.**
7. Remove the wrapping from the In-Line Activated Carbon Post Filter. Slice the 3/8" Blue Polytube where it would be

convenient to install and change the In-Line Filter. Make a clean straight cut to insure proper connections. The "Out" port on the In-Line Filter should be towards the faucet. Firmly press in the tubing. The fittings will grab the tubing and hold and seal it in place. Make sure the tubing is pressed all the way in to create a pressure tight connection.

E. Position the Drinking Water Holding Tank and Make the Final Hose Connections.

1. Check the tank precharge pressure. Make sure it is between 5 to 7 psig. If not, use a bicycle hand pump or other pump to bring the pressure up to the 5 to 7 psig range.
2. Pull the cap/plug off the top of the tank where the Tank Shut-Off should go. (Refer to Fig. 1, page 5.)
3. Wrap the white Teflon tape, included in the box, three times around the 1/4" male outlet thread. Wrap in the direction of the threads (clockwise when looking down on the Holding Tank). The tape will act as a thread sealant. Screw on the Holding Tank Shut-Off Valve.
4. Locate the 3/8" Yellow Tubing. Firmly press one end into the Holding Tank Shut-Off Valve and the other end into the tee. (Refer to Fig. 1, page 5.) The fittings will grab the tubing

and seal it in place. Make sure the tubing is pressed all the way in to create a pressure tight connection.

F. Start Up

1. Installing the modules and membrane and sanitizing the holding tank.
 - Open the Dispensing Faucet by lifting the black handle and close the Holding Tank Shut-Off Valve (the handle should be perpendicular to the valve body).
 - Remove the plug on the underside of the manifold labelled "SEDIMENT/CARBON". Unwrap the Sediment/Carbon Module. Make certain the Module O-ring is pressed firmly in the groove. Engage and firmly tighten the module hand tight only.
 - Remove the plug labelled "Membrane" from the underside of the manifold. Trim top of membrane bag, exposing the white plastic seal. While holding onto bag, insert membrane into manifold. (The O-rings should be up towards the manifold.) Take the remaining housing and insert housing O-ring into its groove. Engage and firmly tighten housing hand tight only.
 - Remove the plug labelled "ACTIVATED CARBON" from the underside of the manifold. Unwrap Activated Carbon Module. Make certain Module O-ring is firmly pressed in groove. Engage and firmly tighten the module hand tight only.
 - Close the Holding Tank Valve.
 - Disconnect the yellow product water tubing that runs from the Holding Tank to the Tee (see Fig. 1, page 5). Put 50 drops of bleach (this is ½ tsp. or 3 ml) into the tubing and reconnect the Tee.
2. Rinsing the system:
 - Slowly open the Feed Water Saddle Valve fully counter clockwise.
 - Open the Holding Tank Valve.
 - Check the Air Gap Window on the Dispensing Faucet to be sure that the drain water is flowing. (Refer to Figure 2A, page 9.) The R.O. System is now making water.
 - Do not open the Faucet for at least 8 hours.
 - Do not use the first three full tanks of water.

CAUTION: The R.O. Membrane is shipped with a preservative in it. To ensure proper

rinsing of the R.O. Membrane it is important to wait at least 8 hours before emptying each tank.

When the Faucet is first opened, expect air and carbon fines (very fine black powder) from the In-Line and Activated Carbon Post Filters to be rinsed out. This is normal for the first tank of water or after the Activated Carbon Post Filters are changed.

SECTION V. OPERATION & MAINTENANCE

A. Normal Operation

1. It is normal for the Total Dissolved Solids (TDS) of the water to be higher than normal during the first 5 gallons of operation; this is due to the sanitizing solution and the new Post Filters. After this water is rinsed to drain, the removal rate should stabilize at a value of greater than 75%. The Water Quality Monitor was designed to measure water quality when the R.O. system is making water. In order to assure you are getting an accurate reading, empty the holding tank, wait 15 minutes until the system begins making water, and then test the TDS with the monitor.
2. R.O. systems produce drinking water at relatively slow rates; it can take up to 5 hours or more to fill the Holding Tank. Normal operation is to let the Holding Tank fill with water and then draw water as is needed. When the pressure in the Holding Tank falls to a given pressure (as the water is being used) the Automatic Shut-Off Valve (ASO Valve) will start water production and the system will refill the Holding Tank. When the Holding Tank is full and no water is being used, the ASO Valve will automatically shut off the feed water to conserve water. The more water that is used (up to the capacity of the system) the better the R.O. system will function. Other uses for the water are flowers, pets and rinsing glassware.

With each use it is recommended that you run the tap for at least 10 seconds prior to using water. This is especially important if the water tap has not been used daily. After periods of non-use, such as a week of vacation, it is better to empty the Holding Tank and allow the system to produce fresh water for use. If the system is not used for 3-4 weeks or longer, it is a good idea to resanitize the system and to change the

prefilter and post filters.

B. Changing Modules

THIS R.O. SYSTEM CONTAINS MODULES WHICH MUST BE REPLACED AT REGULAR INTERVALS TO MAINTAIN PROPER PERFORMANCE. USE ONLY FACTORY APPROVED MODULES.

All individuals should take adequate precautions when changing the filters, including wearing protective gloves, to avoid direct contact with the exhausted filters.

The recommended interval for changing the modules (not the R.O. Membrane) is every six (6) months. Typical T.F.C. Membrane life expectancy is three years. Local conditions may dictate more frequent changes.

NOTE: If the R.O. Membrane is to be replaced, see Sec. IV, F.1–2, page 13, for the proper procedure.

Use a drip pan to catch any water that may spill when the Filter Modules are removed. Refer to Fig. 1 page 3 for component location.

1. Close the Feed Water Saddle Valve by turning fully clockwise and open the Dispensing Faucet by lifting the handle. Allow the Holding Tank to empty.
2. Loosen and remove the Sediment/Carbon Module and the Activated Carbon Module. Discard the modules.
3. To sanitize the system and replace the modules:
 - Unwrap the new Sediment/Carbon Module.
 - Using an eyedropper put 5 ml (this is approximately 1 tsp.) of a good quality unscented 5¼% liquid household chlorine bleach down the center tube of the Module.
 - Check the Module O-ring for proper position in its groove, engage and tighten the Module hand tight only.
 - Unwrap the new Activated Carbon Module.
 - Check the Module O-ring for proper position in its groove, engage and tighten the Module hand tight only.
 - Close the Holding Tank Valve.
 - Disconnect the yellow product water tubing that runs from the Holding Tank to the Tee

(see Fig. 1, page 5). Put 50 drops of bleach (this is ½ tsp. or 3 ml) into the tubing and reconnect it to the Tee.

NOTE: Now is the convenient time to change the In–Line Activated Carbon Post Filter, see Sec. V, C.1–6.

- Slowly open the Feed Water Saddle Valve. When water begins dripping out of the Dispensing Faucet, in the following order, close the Faucet and then open the Holding Tank Valve.
- Do not open the Faucet for at least 8 hours.
- Discard the first three full tanks of water produced, they will contain chlorine.

C. Changing the In–Line Activated Carbon Post Filter

1. Close the Feed Water Saddle Valve by turning fully clockwise.
2. Close the Holding Tank Valve and then open the Dispensing Faucet to release the pressure.
3. Remove the In–Line Activated Carbon Post Filter. Disconnect the used Post Filter by pressing in the connector's collar and at the same time pulling the tube out of the fitting. Unscrew the fittings on the In–Line, re–Teflon tape them and install them on the new Post Filter. Do not over tighten the fittings.
4. Firmly reconnect the polytubes to the new Post Filter. (Refer to Fig. 5, page 15.)
5. Slowly open the Feed Water Saddle Valve.
6. When water begins dripping out of the Faucet, in the following order, close the Faucet and open the Holding Tank Valve. When the Faucet is first opened, expect air and carbon fines (very fine black powder), from the new Post Filter to be rinsed out. This is normal for the first tank of water.

SECTION VI. TECHNICAL DATA

A. Water Quality

Water quality is normally measured with a special meter that measures the water's ability to conduct electricity. The more dissolved solids in the water, the higher the conductivity. The results are usually reported in **Parts per Million** (ppm) or **Milligrams per Liter** (mg/l) of **Total Dissolved Solids** (TDS). (Although technically

IN-LINE ACTIVATED CARBON POST FILTER ASSEMBLY




Figure 5

they are not exactly equal, in most discussions
ppm = mg/l.)

R.O. Membranes are rated by the amount of dissolved solids that are rejected. This rating is a ratio of the TDS in the feed water to the TDS in the product water and is reported as **Percent Rejection**. If the feed water contained 100 ppm of TDS and the product water contained 10 ppm of TDS, 90 ppm have been rejected and the reject ratio is 90%.

$$\text{Percent Rejection} = \frac{\text{Feed TDS} - \text{Product TDS}}{\text{Feed TDS}} \times 100\%$$

EXAMPLE: Feed water is 500 ppm TDS and the product water is 75 ppm TDS.

$$\text{Percent Rejection} = \frac{500 - 75}{500} \times 100\%$$

$$\text{Percent Rejection} = 0.85 \times 100\% \text{ or } 85\%$$

B. Water Quantity

Water quantity is termed **Flux** or **Product Water Rate** and is measured as the amount of water produced in one day. It is reported as **Gallons per Day (gpd)** or **Liters per Day (lpd)**.

The flow of water to drain is the **Reject Water Rate** and is measured as **Gallons per Day (gpd)** or as **Milliliters per Minute (ml/min)**.

$$\text{Milliliters per minute} \times 0.38 = \text{gallons per day}$$

EXAMPLE: The drain flow will fill a graduated cylinder to the 150 ml mark in one minute.

$$150 \text{ ml/min.} \times 0.38 = 57 \text{ gpd}$$

If the container available measures ounces, use the following conversion:

$$\text{Ounces per minute} \times 11.2 = \text{gallons per day}$$

EXAMPLE: The product flow will fill 2½ ounces in two minutes.

$$2.5 \text{ oz.} \div 2 \text{ min.} = 1.25 \text{ oz./min.}$$

$$1.25 \text{ oz./min.} \times 11.2 = 14 \text{ gpd}$$

The **Reject Ratio** is the amount of water produced compared to the amount of water flowing to drain.

$$\text{Reject Ratio} = \frac{\text{Reject Rate}}{\text{Product Rate}}$$

EXAMPLE: The product rate is 14 gpd and the reject rate is 56 gpd.

$$\text{Reject Ratio} = 56 \div 14$$

$$\text{Reject Ratio} = 4 \text{ or } 4\text{--to--}1$$

The **Percent Recovery** is another way to measure the amount of water produced as compared to the amount actually used.

$$\% \text{ Recovery} = \frac{\text{Product Rate}}{\text{Feed Rate}} \times 100\%$$

NOTE: The total flow or feed water rate into the system is the sum of the product flow and the drain flow.

EXAMPLE: The product water rate is 14 gpd and the drain water rate is 56 gpd

$$\text{Feed Rate} = 14 \text{ gpd} + 56 \text{ gpd} = 70 \text{ gpd}$$

$$\% \text{ Recovery} = \frac{14 \text{ gpd}}{70 \text{ gpd}} \times 100\%$$

$$\% \text{ Recovery} = 0.20 \times 100\% \text{ or } 20\%$$

C. Net Pressure Differential

Most R.O. Membranes are rated at a standardized condition of 77°F (25°C) and 65 psig (450kPa) discharging to atmospheric pressure.

Product water quality and quantity greatly depend upon the **Net Pressure Differential (Dp)** across the R.O. Membrane. This pressure differential is a summation of the feed water pressure at the Membrane, which tries to push the water through, the pressure in the Holding Tank, which tries to push the water backwards and the osmotic pressure, which also tries to push the water backwards.

The **Osmotic Pressure** is in proportion to the

dissolved minerals in the water and can be approximated by 1 psig for each 100 ppm of TDS

EXAMPLE: A feed water with 1500 ppm of TDS would exert a backward pressure of about 15 psig on the membrane.

Net Pressure Differential =
Feed Water Pressure – Holding Tank Pressure –
Osmotic Pressure

The higher the net pressure differential, the higher the quantity and quality of water produced.

Some loss of production is normal when using a pressurized Holding Tank.

D. WATER PRODUCTION RATE CHART

| Feed Water | | Estimated Water Production Rate in Gallons Per Day (gpd) and Liters Per Day (lpd) for Line Pressure of: | | | | | | | | | | | | | |
|---------------|--------------|--|------|----------------------|-------|----------------------|-------|----------------------|-------|----------------------|-------|----------------------|-------|-----------------------|-------|
| Temp °F °C | TDS* mg/l | 40 psig (280 kPa) | | 50 psig (345 kPa) | | 60 psig (414 kPa) | | 70 psig (483 kPa) | | 80 psig (552 kPa) | | 90 psig (621 kPa) | | 100 psig (690 kPa) | |
| | | gpd | lpd | gpd | lpd | gpd | lpd | gpd | lpd | gpd | lpd | gpd | lpd | gpd | lpd |
| 40 4 | 50 | 6.5 | 24.6 | 8.5 | 32.2 | 10.5 | 39.7 | 12.5 | 47.3 | 14.5 | 54.9 | 16.5 | 62.5 | 18.5 | 70.0 |
| | 500 | 5.6 | 21.2 | 7.6 | 28.8 | 9.6 | 36.3 | 11.6 | 43.9 | 13.6 | 51.5 | 15.6 | 59.0 | 17.6 | 66.6 |
| | 1000 | 4.6 | 17.4 | 6.6 | 25.0 | 8.6 | 32.6 | 10.6 | 40.1 | 12.6 | 47.7 | 14.6 | 55.3 | 16.6 | 62.8 |
| | 1500 | 3.6 | 13.6 | 5.6 | 21.2 | 7.6 | 28.8 | 9.6 | 36.3 | 11.6 | 43.9 | 13.6 | 51.5 | 15.6 | 59.0 |
| 50 10 | 50 | 9.9 | 37.5 | 12.9 | 48.8 | 15.9 | 60.2 | 19.0 | 71.9 | 22.0 | 83.3 | 25.0 | 94.6 | 28.1 | 106.4 |
| | 500 | 8.5 | 32.2 | 11.5 | 43.5 | 14.6 | 55.3 | 17.6 | 66.6 | 20.6 | 78.0 | 23.7 | 89.7 | 26.7 | 101.1 |
| | 1000 | 7.0 | 26.5 | 10.0 | 37.9 | 13.0 | 49.2 | 16.1 | 60.9 | 19.1 | 72.3 | 22.1 | 83.6 | 25.2 | 95.4 |
| | 1500 | 5.5 | 20.8 | 8.5 | 32.2 | 11.5 | 43.5 | 14.6 | 55.3 | 17.6 | 66.6 | 20.6 | 78.0 | 23.7 | 89.7 |
| 60 16 | 50 | 13.2 | 50.0 | 17.3 | 65.5 | 21.4 | 81.0 | 25.4 | 96.1 | 29.5 | 111.7 | 33.6 | 127.2 | 37.7 | 142.7 |
| | 500 | 11.4 | 43.1 | 15.5 | 58.7 | 19.5 | 73.8 | 23.6 | 89.3 | 27.7 | 104.8 | 31.7 | 120.0 | 35.8 | 135.5 |
| | 1000 | 9.4 | 35.6 | 13.4 | 50.7 | 17.5 | 66.2 | 21.6 | 81.8 | 25.6 | 96.9 | 29.7 | 112.4 | 33.8 | 127.9 |
| | 1500 | 7.3 | 27.6 | 11.4 | 43.1 | 15.5 | 58.7 | 19.5 | 73.8 | 23.6 | 89.3 | 27.7 | 104.8 | 31.7 | 120.0 |
| 70 21 | 50 | 16.6 | 62.8 | 21.7 | 82.1 | 26.8 | 101.4 | 31.9 | 120.7 | 37.0 | 140.0 | 42.1 | 159.3 | 47.2 | 178.7 |
| | 500 | 14.3 | 54.1 | 19.4 | 73.4 | 24.5 | 92.7 | 29.6 | 112.0 | 34.7 | 131.3 | 39.8 | 150.6 | 44.9 | 169.9 |
| | 1000 | 11.7 | 44.3 | 16.9 | 64.0 | 22.0 | 83.3 | 27.1 | 102.6 | 32.2 | 121.9 | 37.3 | 141.2 | 42.4 | 160.5 |
| | 1500 | 9.2 | 34.8 | 14.3 | 54.1 | 19.4 | 73.4 | 24.5 | 92.7 | 29.6 | 112.0 | 34.7 | 131.3 | 39.8 | 150.6 |
| 80 27 | 50 | 20.0 | 75.7 | 26.1 | 98.8 | 32.3 | 122.3 | 38.4 | 145.3 | 44.5 | 168.4 | 50.7 | 191.9 | 56.8 | 215.0 |
| | 500 | 17.2 | 65.1 | 23.3 | 88.2 | 29.5 | 111.7 | 35.6 | 134.7 | 41.8 | 158.2 | 47.9 | 181.3 | 54.1 | 204.8 |
| | 1000 | 14.1 | 53.4 | 20.3 | 76.8 | 26.4 | 99.9 | 32.6 | 123.4 | 38.7 | 146.5 | 44.9 | 169.9 | 50.1 | 189.6 |
| | 1500 | 11.1 | 42.0 | 17.2 | 65.1 | 23.3 | 88.2 | 29.5 | 111.7 | 35.6 | 134.7 | 41.8 | 158.2 | 47.9 | 181.3 |
| 90 32 | 50 | 23.3 | 88.2 | 30.5 | 115.4 | 37.7 | 142.7 | 44.9 | 169.9 | 52.1 | 197.2 | 59.2 | 224.1 | 66.4 | 251.3 |
| | 500 | 20.1 | 76.1 | 27.3 | 103.3 | 34.5 | 130.6 | 41.7 | 157.8 | 48.8 | 184.7 | 56.0 | 212.0 | 63.2 | 239.2 |
| | 1000 | 16.5 | 62.5 | 23.7 | 89.7 | 30.9 | 117.0 | 38.1 | 144.2 | 45.2 | 171.1 | 52.4 | 198.3 | 59.6 | 225.6 |
| | 1500 | 12.9 | 48.8 | 20.1 | 76.1 | 27.3 | 103.3 | 34.5 | 130.6 | 41.7 | 157.8 | 48.8 | 184.7 | 56.0 | 212.0 |

*Total Dissolved Solids (TDS) measured in Parts Per Million (ppm)/Milligrams per Liter (mg/l).

Please Note: This chart is based upon a start-up of a system when the storage tank is empty, (7 psig/48 kPa precharge). As the tank fills, and backpressure from the tank increases, the gpd/lpd rating will decrease.

IMPORTANT! If the water production rate is within the highlighted area (marked with dotted lines), change the drain restrictor to a 125 gpd (473 lpd) drain restrictor, color-coded purple.

SECTION VII. TROUBLE SHOOTING GUIDE


| Problem | Possible Cause | Solution |
|--|--|---|
| Low quantity of Product Water from Holding Tank | Feed Water Saddle Valve is plugged or closed. | Open Valve or unclog. |
| | Clogged Sediment/Carbon Module or Activated Carbon Module. | Replace Modules. |
| | Low water pressure. | Feed Water pressure must be above 40 psig. |
| | R.O. Membrane is fouled. | See Feed Water operating limits. Correct cause of fouling, replace Membrane. |
| | Plugged In-Line Activated Carbon Post Filter. | Replace Post Filter. |
| | Air precharge pressure in Holding Tank is too high. | Empty water from Holding Tank, and with the faucet open, adjust air pressure to 5–7 psig (35–48 kPa) range. |
| | Air precharge is too low | |
| | Air bladder in the Holding Tank is ruptured. | |
| | Holding Tank Valve is closed. | Replace tank. |
| | Holding Tank Valve is closed. | Open Valve. |
| | No drain flow, the Drain Restrictor is plugged. | Clear or replace Drain Restrictor. |
| | No drain flow, the drain orifice in the Air Gap Faucet is plugged. | Clear or replace the Air Gap Faucet. |
| | The Check Valve is stuck. | Free check. |
| | The ASO Valve is malfunctioning. | Replace ASO Valve components. |
| Low pressure at the Dispensing Faucet | In-Line Activated Carbon Post Filter is plugged. | Replace Post Filter. |
| | Air precharge in the Holding Tank is too low. | Empty water from Holding Tank and with the faucet open, adjust the air pressure to 5–7 psig (35–48 kPa) range. Check for leakage at the Air Valve Stem. |
| | Holding Tank Valve is partially closed. | Open Valve. |
| | The dispensing Faucet is out of adjustment or faulty. | Repair or replace Dispensing Faucet. |
| | Heavy water use, Holding Tank is depleted. | Allow Holding Tank to refill (adding a second Holding Tank will increase storage capacity). |
| | Low Water Production. | See Low Quantity of Product Water from Holding Tank section above. |
| | High Total Dissolved Solids (TDS) in the Product Water | Clogged Sediment/Carbon Module or Activated Carbon Module. |
| Low Water Pressure. | | Feed Water Pressure must be above 40 psig. Check Feed Water Saddle Valve. |
| R.O. Membrane O-ring is crimped. | | Check O-ring. |
| R.O. Membrane brine seal is not sealing up into the manifold head. | | Check the brine seal. |
| R.O. Membrane is expended. | | If Membrane life is unusually short, find and correct the problem. Replace Membrane. |


| Problem | Possible Cause | Solution |
|---|--|--|
| High Total Dissolved Solids (TDS) in the Product Water (continued) | The Product Water and Drain Water lines are reversed. | Correct plumbing. |
| | No drain flow, Drain Restrictor is clogged. | Clear or replace Drain Restrictor. |
| | No drain flow, the drain orifice in the Air Gap Faucet is plugged. | Clear or replace Air Gap Faucet.. |
| | The ASO Valve is not closing. | Repair or replace the ASO Valve Components. |
| | New Activated Carbon Post Filter not rinsed completely. | Flush with several full tanks of Product Water. |
| | The Feed Water TDS has increased. | An increase in Feed Water TDS will give a corresponding increase in Product Water TDS. |
| Tastes and odors in the Product Water | The Activated Carbon Post Filter is exhausted. | Replace Filter. |
| | There is foreign matter in the Holding Tank. | Clean, flush and sanitize the system. Replace the filters. |
| | The Product Water and Drain Water lines are reversed. | Correct plumbing. |
| | Dissolved gasses in the Feed Water. | Pretreat Feed Water to remove dissolved gasses. |
| | Increase in Product Water TDS. | See high TDS in the Product Water section. |
| Drain Water overflows at the Air Gap Faucet | Air Gap is blocked. | Clear Air Gap. Rinse with vinegar for removal of calcium buildup. |
| | Drain tubing is clogged. | Clear tubing. |
| | Drain Clamp hole is misaligned. | Align with hole in the drain pipe. |
| | Excessive drain flow rate. | Replace Drain Restrictor. |
| Faucet leaks or drips | Leaks from spout. | Adjust Faucet by turning the tee bar just below the handle to provide a small amount of free play in handle when shut off. O-rings are bad, repair or replace faucet. |
| | Leaks from base of the delivery tube. | O-ring is bad, replace O-ring. |
| | Leaks from beneath the handle. | O-rings are bad. Repair or replace the faucet. |
| Amber light on Water Quality Monitor | System not being used for extended period of time | Empty storage tank. Wait 15 minutes (the system is making water) and test water quality again. |
| | Filters are plugged or membrane is fouled or exhausted. | Replace filters and/or membrane. |
| Fitting leaks in general | Close the Feed Water Saddle Valve and relieve pressure before disconnecting any tubing or replacing any fitting. Before replacing a fitting, re-cut the tubing and re-insert into the fitting to see if that solves the leak. If pipe threads are leaking, remove and retape with Teflon tape. | |

NOTES:

EXPLODED VIEW & PARTS LIST

21. Nitrate/Nitrite Test Kit





| DRAWING NO. | PART NO. | DESCRIPTION |
|-----------------------|--------------|--|
| 1..... | S2009..... | Self Tapping Screw |
| 2..... | S2005..... | ASO Cap |
| 3..... | S2013..... | ASO Cap O-Ring |
| 4..... | S2011..... | ASO Diaphragm – Large |
| 5..... | S2007..... | ASO Piston |
| 6..... | S2006..... | ASO Piston Ring |
| 7..... | S2010..... | ASO Diaphragm – Small |
| 8..... | S2128-M..... | Manifold Plate |
| 9..... | S1276..... | Check Valve |
| 10..... | S1277..... | Check Valve Retainer |
| 11..... | S7128X..... | Sediment/Carbon Module |
| 12..... | S1448RS..... | T.F.C. RO Membrane 35 gpd/132 lpd |
| 13..... | S3069..... | Housing O-Ring |
| 14..... | S3010..... | Housing |
| 15..... | R7078..... | Water Quality Monitor w/Probes and Cover |
| 16..... | S2116-8..... | Drain Restrictor 80 GPD/303 lpd Blue |
| 17..... | S7125X..... | Activated Carbon Module |
| 18..... | S1405..... | 1/4"-3/8" Fitting Wrench |
| 19..... | S3072..... | Wrench for Housing |
| 20..... | S7206W..... | In-Line Activated Carbon Post Filter |
| 21..... | S1447..... | Nitrate/Nitrite Test Kit |
| (shown on pg. 6) | R2118..... | Water Quality Monitor 25 Ft. Extension Cable |

OTHER COMPONENTS AS SHOWN IN FIGURE 1, PAGE 5.

| DRAWING NO. | PART NO. | DESCRIPTION |
|-------------|-------------------|---|
| 1..... | S1089-08..... | Long Reach Air Gap Faucet w/ 3/8" Connector |
| 2..... | R7091-01BLK..... | Water Quality Monitor Faucet Base |
| 3..... | S1117-01..... | 3/8" Drain Clamp Assembly |
| 4..... | S2122..... | Cover |
| 7..... | JG-PI301208S..... | 3/8" x 3/8" x 1/4" Union Tee |
| 8..... | S1118-01..... | Feed Water Saddle Valve |
| 9..... | C2000..... | Steel Holding Tank |
| 10..... | S1037..... | Holding Tank Shut-Off Valve |

ECLIPSE™ R.O. DRINKING WATER SYSTEM

FIVE/ONE YEAR LIMITED WARRANTY

What Does This Warranty Cover?

This warranty covers any defects in materials and workmanship of the Eclipse R.O. Drinking Water System when installed and operated within recommended parameters, with the exceptions stated below.

How Long Does The Coverage Last?

Water-Right® will warrant its Eclipse R.O. Drinking Water System (except for the reverse osmosis membrane), for a period of five years from the date of purchase. The reverse osmosis membrane is warranted for one year from date of purchase. All implied warranties including merchantability and fitness for a particular purpose are limited to five years from the date of purchase for the Eclipse R.O. Drinking Water System, except for the reverse osmosis membrane which is limited to one year from date of purchase. Some states do not allow limitations on how long an implied warranty lasts, so the above limitations may not apply to you.

What Will Water-Right® Do?

Water-Right® will repair or replace at its discretion any defective component. You must pay any labor charges. You must also pay for shipping or travel charges to return the defective part(s).

What Does This Warranty Not Cover?

This warranty does not cover the disposable sediment and carbon filters whose service life depends on feed water conditions. In addition, the membrane is only warranted if the required feed water conditions are met.

The above warranty will also not apply to any part of the Eclipse R.O. Drinking Water System that is damaged because of neglect, misuse, alterations, accident, misapplication, physical damage, or damage caused by fire, acts of God, freezing or hot waters or similar causes. Consequential and incidental damages are not recoverable under this warranty. Some states do not allow the exclusion or limitation of incidental or consequential damages, so the above limitation or exclusion may not apply to you.

We recommend that you use only authorized Eclipse replacement parts since improper parts or incorrectly performed maintenance or repair voids this warranty. In addition, if non Eclipse parts are used, contaminant reduction claims, certifications to/from NSF/ANSI Standard 58, and/or state approvals are no longer valid.

How Do You Get Service?

In order to be eligible for service under this warranty you must (a) contact your local dealer who supplied the unit or (b) contact the factory for the dealer nearest you.

How Does State Law Apply?

This warranty gives you specific legal rights and you may also have other rights which vary from state to state.



1900 Prospect Court
Appleton, WI 54915
Phone: 920-739-9401
1-800-777-1426
FAX: 920-739-9406